

NOTES:

- 1. ALL FITTINGS TO BE BRASS OR COPPER FROM WATER MAIN TO 1" AIR & VACUUM ASSEMBLY.
- 2. AIR & VACUUM RELEASE VALVE ASSEMBLY MUST BE INSTALLED AT THE HIGHEST POINT OF THE LINE. IF THE HIGH POINT FALLS IN A LOCATION WHERE ASSEMBLY CANNOT BE INSTALLED, PROVIDE ADDITIONAL DEPTH OF LINE TO CREATE HIGH POINT AT A LOCATION WHERE ASSEMBLY CAN BE INSTALLED.

CITY OF THE TOTAL PROPERTY OF THE PROPERTY OF	APPROVED BY DATE	L. OLIVE 07/31/2008	DEPARTMENT OF PUBLIC WORKS STANDARD DETAILS	STANDARD DETAIL NUMBER
	REF STAD SPEC		1" COMBINATION AIR VALVE ASSEMBLY	
				W-260